



# Compliance Statement

## Screened Category 6<sub>A</sub> ISO/IEC, EN & TIA Connecting Hardware

**Assmann Identification P/N DN-93615**

**Category 6<sub>A</sub>, Screened, Keystone Jack  
Electrical Transmission Performance**

**Assmann Electronic GmbH**

**Auf dem Schüffel 3**

**DE-58513 Lüdenscheid**

**Compliance Statement No. 111640**

*This Screened ISO/IEC, CENELEC & TIA Connecting Hardware having board identification "KJ28", has been tested by 3P Third Party Testing and complies with the Category 6<sub>A</sub> transmission requirements of Amendment 2 to 2<sup>nd</sup> edition ISO/IEC Generic Cabling Standard 11801, Amendment 2 to CENELEC EN 50173-1 (draft FprAB July 2010) and IEC Connecting Hardware Standard 60603-7-51, Category 6A transmission requirements of ANSI/TIA Generic Cabling Standard 568-C.2, and IEC test standard 60512-27-100 (draft 48B/2060/CD). The requirements are passed for both sides of the modular jack using the complete specified re-embedded range of RJ 45 plug vectors. The qualification activity includes factory and assembly line inspection. The Compliance Statement may be suspended or withdrawn if the modular jack fails to pass a Maintenance Testing performed at 12 month intervals.*

Hoersholm, 16<sup>th</sup> June 2011

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 16<sup>th</sup> June 2011

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager